


Format No. NSPL/LAB/7.8/F/02

TEST REPORT					
Sample Inward		NSPL/26-27/03/DW/79		ULR	TC1192226000000319F
Report No.		NSPL/EL/26-27/03/20/79		Issue Date	23/03/2026
Name and Address of Customer*		M/s. Orbis School - 1 Keshav Nagar , Pune 2 Mundwa.			
Discipline		Chemical	Date of Sample Collection		20/03/2026
Group		Water	Date of receipt of sample in lab		20/03/2026
Sub Group		Water-Drinking Water	Sample Quantity		01 Liter Plastic Can
Sample Description		RO water (Sample -1)	Sample Status		Sealed
Sample collected by*		Client			
Start Date of Analysis		20/03/2026		End Date of Analysis	23/03/2026
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (IS 10500:2012) Max	Methods
Chemical Parameter					
1	pH at 25°C	6.67	-	6.5 to 8.5	APHA24 th edition 4500 H ⁺ :B
2	Electrical Conductivity at 250C	104.4	µS/cm	800	APHA 24 th edition 2510-B
3	Turbidity	<1	NTU	1	APHA24 th edition 2130: B
4	Total Dissolved Solids	52	mg/l	500	APHA24 th edition 2540: C
5	Total Alkalinity (as CaCO ₃)	8	mg/l	200	APHA24 th edition 2320: B
6	Total Hardness (as CaCO ₃)	34.02	mg/l	200	APHA24 th edition 2340: C
7	Calcium as Ca	4.80	mg/l	75	APHA24 th edition 3500-Ca-B
8	Magnesium (as Mg)	5.35	mg/l	30	APHA24 th edition 3500-Mg*2:B
9	Chloride (as Cl)	6.99	mg/l	250	APHA24 th edition 4500: Cl-B
10	Residual Chlorine	BDL	mg/l	Min 0.2	APHA24 th edition 4500: Cl-B
11	Sulphate (as SO ₄)	<2	mg/l	200	APHA24 th edition 4500-SO ₄ : E
Physical Parameters					
1	Color	<1	Hazen Unit	Max 5	APHA24 th edition 2120: B
2	Odour	Agreeable	--	Agreeable	IS 3025 (Part-5)

*****End of Report*****

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NSPL.


(Priyanka Kajale)
Technical Manager
Reviewed By




(Sonal Dagade)
Quality Manager
Authorized Signatory



NIRVIECO SOLUTIONS PRIVATE LIMITED.
ENVIRONMENTAL LABORATORY.
SR.No.146,GHAWATE VISION,MANJARI GHAWATE VASTI ROAD,
MANJARI BUDRUK PUNE,MAHARASHTRA-412307
MOBILE: 9284183339 E-MAIL: NIRVIECOSOLUTIONS@GMAIL.COM

TEST REPORT					
Sample Inward	NSPL/26-27/03/DW/79		Issue Date	23/03/2026	
Report No.	NSPL/EL/26-27/03/20/79A				
Name and Address of Customer*	M/s. Orbis School - <i>Mundwa</i> Keshavnagar, Pune				
Discipline	Chemical	Date of Sample Collection	20/03/2026		
Group	Water	Date of receipt of sample in lab	20/03/2026		
Sub Group	Water-Drinking Water	Sample Quantity	01 Liter Plastic Can		
Sample Description	RO water (Sample -1)	Sample Status	Sealed		
Sample collected by*	Client				
Start Date of Analysis	20/03/2026	End Date of Analysis	23/03/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (IS 10500:2012) Max	Methods
1	Total Coliform	Absent	MPN/100ml	Absent	IS 1622
2	E.Coli	Absent	MPN/100ml	Absent	IS 1622

*****End of Report*****

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NSPL.

Priyanka

(Priyanka Kajale)
Technical Manager
Reviewed By



Sonal

(Sonal Dagade)
Quality Manager
Authorized Signatory